



# Certificate of Compliance

This certificate is issued for the following:

## Steel Pipe for Use with Aboveground Fire Protection Systems

### Pipe Specification

ASTM A795  
ASTM A53  
ASTM A53  
EN 10255  
EN 10255

### Pipe Schedule

Schedule 10  
Schedule 40  
Schedule 80  
Medium  
Heavy

### Pipe Size

10 and 12 inch NPS  
1/2 and 3/4 inch NPS  
1/2 and 3/4 inch NPS  
33.7 through 165.1 mm NPS  
21.3 through 165.1 mm NPS

### Prepared for:

Borusan Mannesmann Boru  
Hisar Mahallesi Gemsaz Mevkii  
16601 Gemlik – Bursa  
Turkey

### Manufactured at:

Borusan Mannesmann Boru  
Hisar Mahallesi Gemsaz Mevkii  
16601 Gemlik – Bursa  
Turkey

FM Approvals Class: 1630 – “Steel Pipe for Automatic Fire Sprinkler Systems”

Approval Identification: 3046815

Approval Granted: August 28, 2014

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in dark ink, appearing to read "Richard B. Dunne".

Richard B. Dunne  
Manager, Fire Protection  
FM Approvals  
1151 Boston-Providence Turnpike  
Norwood, MA 02062



*Member of the FM Global Group*